S5509QT

4

NONE

5/23/90

APPROVED BY

P

CHECKED BY

DRAWN BY **JLO** 

FIGURE NUMBEF DATA

VOID

OR

SUPERSEDED

FOR USE OF

NO RESPONSIBILITY

ASSUME

CAN

 $\mathbb{A}$ 

CHANGE WITHOUT NOTICE

**AND** 


DRAWING NUMBER

## QUARTERHORSE 1/4 TURN NON-FREEZE WALL HYDRANT WITH INTEGRAL VACUUM BREAKER AND STAINLESS STEEL BOX

#### **BOX TYPE WITH CONCEALED HOSE CONNECTION**

**FUNCTION:** Provides positive non-freeze protection where water is required at the outside of the building and features an integral vacuum breaker. The stainless steel recessed box conceals the nozzle and operating mechanism. The locking cover prevents unauthorized use.

1/4 Turn of the Key Allows Full Flow to Be Obtained



at the hydrant to box interface and hydrant to wall interface. Seal all interior joints, seams, gasket seams/closures including around the hydrant box flange with an appropriate sealant recommended by a sealant manufacturer. NOTE: Jay R. Smith does not warrant the performance or life expectancy of the sealant material.

#### **REGULARLY FURNISHED:**

Bronze Nickel Plated Quarter Turn Self Draining Non-Freeze Hydrant with Hose Connection, Integral Vacuum Breaker, "T" Handle Key, and Stainless Steel Box with Full 180° Cover Opening.

# VARIATIONS: Adjustable Wall Clamp -WC Cylinder Lock -CL 1" (25) Hose Connection -HC1 1" (25) Male NPT Inlet Connection -IC1

OPTIONAL MATERIALS:
Nickel Bronze Box Face -NB
Polished Bronze Box Face -PB
Rough Bronze Box Face -RB
Chrome Plated Face -CP

\*\*Add 3/4" (19) to Overall Length When Specified

NOTES: \*1. Recommended wall opening 6"(150) x 6"(150). Hydrant shall be in the vertical position only, the connection must be on the bottom.

"Water" On Cover -W

- 2. When ordering, specify wall thickness in  $2^{\circ}(51)$  increments as follows: 06(150), 08(205), 10(255), 12(305), 14(355), 16(405), 18(455), 20(510), 22(560) or 24(610). When wall clamp -WC is desired, increase wall thickness dimension by  $2^{\circ}(51)$ .
- 3. All Jay R. Smith hydrants are manufactured with "NO-LEAD" brazing rings, and USDA approved lubricants.
- 4. When an Optional Box Face Material is Specified a Concealed Hinge will be Provided, also Add 1/4"(6) to Flange Thickness.
- 5. The AB1953, California Lead Law, and NSF/ANSI Standard 61-2008 Drinking Water System Components are not applicable to Jay R. Smith hydrants as they do not convey/dispense water for human consumption through drinking or cooking.
- 6. Dimensions shown in parentheses are in millimeters.

FIG. 5509QT

- 7. FOR IRRIGATION PURPOSES ONLY.
- For the hydrant to drain properly and provide non-freeze protection when used with a hose, the Hose must be removed from the nozzle after each use.

  PATENTED

U T S R	3-26-19 7-18-16 1-31-13 6-13-11	Added Note Added Note Revised Notes Revised Note	MW TBW TBW TBW	CR BW CL CL	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER  5509QT
REV.	DATE	DESCRIPTION	BY	CKD. BY			3303Q1

S5509QTBS

NONE

1-3-90

APPROVED BY ₽

CHECKED BS

DRAWN BY

5509QT-BS


FIGURE NUMBER

DRAWING NUMBER



LOCATION

### **HYDRANT PARTS LIST**



- Δ These Replacement Parts Available in HPRK-7
- All Parts Accessible from Face of Hydrant by Removing Face Nut.

	HYDRANT PARTS LIST								
NO.	DESCRIPTION	NO.	DESCRIPTION	NO.	DESCRIPTION				
1	Head/Casing Assembly	10	Operator Rod	13a	Retaining Ring				
1a	Head	11	Face Nut Washer	13b	Valve Body				
1b	Casing	12	Vacuum Breaker Assembly	13c	Valve Actuator				
1c	Valve Housing	12a	VB Cap	13d	Nylon Thrust Washer				
3	Key	12b	VB Body	13e	Rotating Ceramic Disc				
7	Face Nut	12c	VB Washer	13f	Fixed Ceramic Disc				
8	Actuator Shaft	12d	VB "O" Ring	13g	Silicon Rubber Seal				
9 Actuator "O" Ring		12e	VB Piston	13h	Retainer Guide (2)				
		13	Valve Body Assembly	14	Box Assembly S.S.				

G F E D	7-18-16 5-21-92 10-25-91 12-90	Added Note Changed Repair Pts. Update Figure Number Rev Dwg	TBW TWK TWK EMB	BW JCS JCS JCS	_	VOLUME CUBIC FEET	FIGURE NUMBER  5509QT-BS
REV.	DATE	DESCRIPTION	BY	CKD. BY			